

SITE UTILIY NOTES:

1. THIS DRAWING DOES NOT PURPORT TO LOCATE ALL UTILITIES.
2. EXISTING UTILITIES SHALL BE VERIFIED IN FIELD PRIOR TO ANY EXCAVATION OR INSTALLATION OF ANY NEW WATER LINES.
3. WATER LINES TO MAINTAIN A MINIMUM PARALLEL SEPARATION OF 10 FEET FROM SANITARY SEWER LINES, 5 FEET FROM ALL OTHER UNDERGROUND UTILITIES. WHEN CROSSING, MAINTAIN A VERTICAL SEPARATION OF 18 INCHES. THE SEWER LINE SHALL BE OF DUCTILE IRON WITH MECHANICAL JOINTS AT LEAST 10 FEET ON BOTH SIDES OF THE CROSSING.
4. ALL WORK AND MATERIALS SHALL COMPLY WITH HAMILTON COUNTY AND EASTSIDE UTILITY DISTRICT REGULATIONS AND CODES AND O.H.S.A. STANDARDS.
5. LINES UNDERGROUND SHALL BE INSTALLED, TESTED AND APPROVED BEFORE BACKFILLING.
6. CONTRACTOR TO CONTACT EASTSIDE UTILITY DISTRICT TO COORDINATE INSTALLATION AS REQUIRED.
7. ALL FIRE HYDRANTS INSTALLED FOR THIS DEVELOPMENT SHALL BE OF A TYPE ACCEPTABLE TO EASTSIDE UTILITY DISTRICT AND HAMILTON COUNTY OR BRADLEY COUNTY SPECIFICATIONS.
8. COORDINATE WITH EASTSIDE UTILITY DISTRICT AS REQUIRED FOR METER INSTALLATION.
9. WATER MAIN TO HAVE A MINIMUM OF 30" COVE PER EASTSIDE UTILITY DISTRICT.
10. ALL WATER LATERALS TO HAVE A MINIMUM OF 18" COVER PER EASTSIDE UTILITY DISTRICT.
11. CONTRACTOR SHALL BE A STATE OF TENNESSEE LICENSED CONTRACTOR APPROVED TO INSTALL PUBLIC WATER MAINS.
12. LUBRICANTS SHALL BE NON-TOXIC AND SHALL NOT PROMOTE BIOLOGICAL GROWTH.
13. PROCEDURES FOR DISINFECTING PORABLE WATERLINES SHALL CONFORM TO THE REQUIREMENTS OF A.W.W.A. C651. ALL WATERLINES SHALL BE DISINFECTED, BATERIOLOGICAL TESTED, AND PRESSURE TREATED ACCORDING TO EASTSIDE UTILITY DISTRICT SPECIFICATIONS PRIOR TO LINE ACCEPTANCE AND THE WATERLINE BEING PLACED INTO SERVICE.
14. PRESSURE AND LEAKAGE TESTS SHALL BE PREFORMED IN STRICT ACCORDANCE WITH CURRENT A.W.W.A. STANDARD C600 AND/OR MANUFACTURER'S PROCEDURES.
15. ALL VALVES AND FITTINGS ARE TO CONFORM TO THE LATEST A.W.W.A. STANDARDS.
16. THE CONTRACTOR SHALL MAKE ARRANGEMENTS WITH THE UTILITY COMPANY FOR CONNECTION TO THE EXISTING UTILITY LINES. THE CONTRACTOR SHALL ADJUST THE LOCATION OF THE PROPOSED WATERLINE TO AVOID CONFLICTS WITH OTHER UTILITIES.
17. ALL CONCRETE USED FOR THRUST BLOCKS TO HAVE A MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 3000 PSI.
18. THE CONTRACTOR IS RESPONSIBLE FOR THE COMPLETE INSTALLATION OF THE WATER SERVICE LIND AND FIRE LINE AS REQUIRED. THE CONTRACTOR SHALL PROVIDE A TAPPING VALVE AND SLEEVE AND OTHER MATERIAL AND EQUIPMENT AS REQUIRED FOR TAPPING THE EXISTING MAIN. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE FEE TO EASTSIDE UTILITY DISTRICT AS REQUIRED FOR TAPPING THE EXISTING MAIN AND COORDINATE WITH EASTSIDE AS REQUIRED. THE CONNECTION TO THE EXISTIING MAIN SHALL BE MADE BY EASTSIDE UTILITY DISTRICT.
19. ALL DETAILS TO SERVE AS REFERENCE ONLY. EASTSIDE UTILITY DISTRICT DETAILS, SPECIFICATIONS AND INSPECTION TO TAKE PRIMACY.

20. THE DEVELOPER MUST PROVIDE EASTSIDE UTILITY, UPON COMPLETION OF THE PROJECT, AN ARCGIS SHAPEFILE OF THE DEVELOPMENT IN QUESTION THAT INCLUDES METER LOCATIONS, VALVE LOCATIONS, FIRE HYDRANT LOCATIONS, WATER MAIN LOCATIONS AND ANY OTHER PERTINENCES INCLUDED IN THE DEVELOPMENT.
21. EASEMENTS OF 10 FEET ARE REQUIRED FOR WATERLINES RANGING UP TO 12 INCHES IN DIAMETER. SIZES EXCEEDING 12 INCHES IN DIAMETER WILL REQUIRE AN EASEMENT OF A MINIMUM OF 15 FEET OR LARGER BUT WILL BE SUBJECT TO DELIBERATION BY OUR AUTHORITY.
22. IF A BEND IS REQUIRED FOR INSTALLATION OF THE WATERLINE, AND IT IS APPROVED BY THE INSPECTOR, (2) MJ SLEEVES MUST BE INSTALLED ONE ON EACH SIDE OF THE BEND, ALONG WITH 100' FIELD-LO GASKETS BEFORE AND AFTER SLEEVES.

MATERIAL NOTES:

1. WATER MAIN SHALL BE AS INDICATED ON PLANS: DUCTILE IRON PIPE CLASS 50, 200 PSI PER ANSI A-21.50 (AWWA C-151) AND ANSI A-21.10 (AWWA C-110). WATER MAINS SMALLER THAN 3": COPPER TUBE TYPE "K" (SOFT) PER ANSI 816.22.
2. WHERE UNDERGROUND WATER MAINS AND HYDRANTS ARE TO BE PROVIDED, THEY MUST BE INSTALLED, COMPLETED, AND IN SERVICE PRIOR TO CONSTRUCTION WORK (NFPA 241 6.7.2.2).